

GOVERNMENT OF NAGALAND STATE WATER QUALITY TESTING LABORATORU PHED, DIMAPUR: NAGALAND

Water Quality Analysis Report

Sample ID No	1021033		
Date of sample collection:	28/10/2021		
Date of sample delivery at the Lab:	28/10/2021		
Customer Name and Address:	Shemrock School		
	Diphupar A Khel, Dimapur		
	•		
Test Commenced on :	28/10/2021		
Test Completed on:	29/10/2021		
SAMPLE	DETAILS FURNISHED BY CUSTOMER		
Source :	R O Filter		
Location:	Diphupar A Khel, Dimapur		
Sample collected by:	Customer		
Quantity Received:	1 L		
Sample Container:	Plastic bottle		
Condition of Sample:	Good condition		

The test result of sample received is as follow.

SI.		BIS 10500:2012	Test Method	Test Values
No	I. PHYSICAL PARAMETERS	Desirable Limits		
1	Color	5 Hazen Unit	APHA 23 rd Edition 2120 B	01
2	Taste		Qualitative	Agreeable
3	Odor		Qualitative	Agreeable
4	pH at 25°C	6.5-8.5	APHA23 rd Edition 4500 –H ⁺ B	7.52
5	Turbidity	1 NTU	APHA23 rd Edition 2130 B	0.65
6	Total Dissolved Solids mg/L	500 mg/L	APHA23 rd Edition 2540 C	14.8
	II.CHEMICAL PARAMETERS			
7	Total Hardness	200 mg./L as CaCO ₃	APHA23 rd Edition 2340 C	20
8	Calcium	75 mg/L as CaCO ₃	APHA23 rd Edition 3500-Ca-B	08
9	Magnesium	30 mg/L as Mg	APHA23 rd Edition 3500-Mg	2.8
10	Total Alkalinity	200 mg/L as CaCO ₃	APHA23 rd Edition 2320 B	60
11	Chloride	250 mg/L as Cl	APHA23 rd Edition 4500-Cl ⁻ B	24
12	Iron	1.0 mg/L as Fe ⁺²	Photometer (Palintest- 7100)	0.05
13	Nitrate	45 mg/L as NO ₄	Photometer (Palintest- 7100)	Nil
14	Free Chlorine	0.2 mg/L	Photometer (Palintest- 7100)	NT
15	Fluoride	1.0 mg/L	Photometer (Palintest- 7100)	0.07
16	Bacteriological Contamination	Negative	H ₂ S vial Strip Test	Negative

Prepared & Verified by

Authorized Signatory A. Rolland Kikon Chemist

SWQTL,PHED, Dimapur: Nagaland

Note:

BDL -Below Detection Level, NT- Not Tested

The test results relates only to the tested sample.

The report shall not be produced in full or part without the written approval of Quality Manager, SWQTL, PHED, Dimapur;: Nagaland.

The test items will not be retained for more than 15 days from the date of issue of test report.